

Confirmation

LEED

On 9 February 2015, Eurofins Product Testing A/S received a sample of a Smoke and acoustic sprays with the product name:

CP572

supplied by

Hilti Entwicklungsgesellschaft GmbH


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000 and CDPH testing standards (See test report no. 392-2016-00056902_H_EN).

The test results of the tested coating indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of CDPH-IAQ (California Department of Public Health); and a TVOC below 0.5 mg/m³ in office.

11 March 2016


Janne R. Norup
Chemist


Thomas Bjerring
Analytical Service Manager