

# Confirmation

## LEED v4.1

On 10 October 2019, Eurofins Product Testing A/S received a sample of a sealant with the product name:

### **CFS -EOS WS**

supplied by

### **Hilti, Inc**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, CDPH 01350 ASTM D2369 testing standards (See test report no. 392-2019-00402401\_H\_EN and no. 392-2019-00486101\_XG\_EN).

**The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions and VOC content by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- The requirements of Option 1 of LEED v4.1 BETA (July 2019): CDPH-IAQ (California Department of Public Health (CDPH) Standard Method v1.2-2017 (worst case relative to v1.0-2010)); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

**VOC content specifications in LEED EQ credit "Low-emitting products":**

- The requirements of the South Coast Air Quality Management District (SCAQMD) Rule 1168 (2017) regarding other sealant having a VOC content below 420 g/L.

16 January 2020



Janne Rothmann Norup  
Analytical Service Manager

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*