



88 Empire Drive • St. Paul, Minnesota • 55103
(651) 642-1150 • fax (651) 642-1239

VOC Content Test Certificate

June 25, 2020

Supplier: Hilti Entwicklungsgesellschaft mbH
BU Chemicals
Hiltistrasse 6
86916 Kaufering
GERMANY

Sample Description: CFS-S SIL GG

Date Tested: June 4, 2020

Test Method: SCAQMD method 304-91 "Determination of Volatile Organic Compounds (VOC) in Various Materials" as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168. The values also comply with the requirements of EPA test method #24.

Test Data:

Specification	Product
LEED 4.1 Low-Emitting Materials – Adhesives and Sealants	CFS-S SIL GG
Green Building Council of Australia Green Star Office Design 3.0, IEQ-13 Green Star Office Design 2.0, IEQ-13 Green Star Office Interiors 1.1, IEQ-11	
All Other Sealants VOC Limit: 420 g/L	Product contains: 41 g/L of VOC

Tom Barrett
Vice President/Strategic Analytical Services