

Confirmation

LEED

On 27 April 2017, Eurofins Product Testing A/S received a sample of a firestop device with the product name:

Firestop Cast-in Device CFS-CID M 10”

supplied by

Hilti Inc.


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH testing standard (See test report no. 392-2017-00147003_H_EN_02).

The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- the requirements of CDPH-IAQ (California Department of Public Health, Feb 2010); and a TVOC below 0.5 mg/m³ in both office and class room.

16 June 2017



Janne R. Norup
Chemist



Maria Pelle
Chemist

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.