

# Confirmation

## LEED

On 27 April 2017 Eurofins Product Testing A/S received a sample of a firestop device with the product name:

### **Firestop Cast-in Device CFS-CID P 8"**

supplied by

**Hilti Inc.**


The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant CDPH testing standard (See test report no. 392-2017-00147001\_H\_EN\_02).

**The test results of the tested product indicate that the product qualifies for LEED v4 specifications on VOC emissions by complying with:**

**VOC emissions specifications in LEED EQ credit "Low-emitting products":**

- the requirements of CDPH-IAQ (California Department of Public Health, Feb 2010); and a TVOC below 0.5 mg/m<sup>3</sup> in both office and class room.

16 June 2017

  
\_\_\_\_\_  
Janne R. Norup  
Chemist

  
\_\_\_\_\_  
Maria Pelle  
Chemist

*LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.*