



Classified by Underwriters Laboratories, Inc. to UL 1479 and CAN/ULC-S115



System No. C-AJ-8333

CAJ 8333

| | |
|---------------------------------------|---|
| ANSI/UL1479 (ASTM E814) | CAN/ULC S115 |
| F Rating — 2 Hr | F Rating — 2 Hr |
| T Rating — 1/2 or 2 hour (See Item 2) | FT Rating — 1/2 or 2 hour (See Item 2) |
| | FH Rating — 2 Hr |
| | FTH Rating — 1/2 or 2 hour (See Item 2) |

TOP VIEW

SECTION A-A



Reproduced by HILTI, Inc. Courtesy of Underwriters Laboratories, Inc. November 10, 2022

System No. C-AJ-8333

CAJ 8333

System tested with a pressure differential of 2.5 Pa between the exposed and the unexposed surfaces with the higher pressure on the exposed side.

1. Floor or Wall Assembly — Min 4-1/2 in. (114 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete floor. Min 5 in. (127 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) concrete wall. Wall may also be constructed of any UL Classified Concrete Blocks*. Max area of square, rectangular, or circular opening is 160 in². (1032 cm²) with a max dimension of 32 in. (1219 mm).

See Concrete Blocks (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. Through-Penetrant — One or more penetrants may be installed within the opening. The total number of through-penetrants is dependent on the size of the opening and the types and sizes of the penetrants. Any combination of the penetrants described below may be used provided that the following parameters relative to the annular spaces are maintained. The annular space between penetrants and the edge of the opening shall be min 1/2 in. (13mm) to max 5 in. (127 mm). The annular space between rigid nonmetallic penetrants shall be min 1/2 in. (13mm). The annular space between rigid nonmetallic conduit and steel conduit shall be min 1 in. (25mm). The annular space between vented PVC pipe and steel conduit shall be min 2 in. (51mm). Penetrants to be rigidly supported on both sides of floor or wall assembly. The following types and sizes of penetrants may be used.

A. Metallic Pipes — The following types of conduit may be used:

1. Conduit — Nom 2 in. (152 mm) diam (or smaller) rigid steel conduit or electrical metal tubing (EMT)

When any of the above metallic penetrants are used, the T Rating, FT Rating, and FTH Rating are limited to 1/2 hr.

B. Nonmetallic Pipes — The following nonmetallic pipes may be used:

1. Polyvinyl Chloride (PVC) Pipe — Nom 2 in. (51 mm) diam (or smaller) Schedule 40 cellular or solid core PVC pipe for use in closed (process or supply) or vented (drain, waste or vent) piping systems.

2. Chlorinated Polyvinyl Chloride (CPVC) Pipe — Nom 2 in. (51 mm) diam (or smaller) SDR13.5 CPVC pipe for use in closed (process or supply) piping systems.

3. Rigid Nonmetallic Conduit++ — Nom 2 in. (51 mm) diam (or smaller) (Schedule 40) PVC conduit installed in accordance with Article 347 of the National Electric Code (NFPA No. 70).

When any of the above nonmetallic penetrants are used in closed (process or supply) systems, the T Rating, FT Rating, and FTH Rating are max 2 hr. When any of the above nonmetallic penetrants are used in vented (drain, waste or vent) systems, the T Rating, FT Rating, and FTH Rating are limited to 1/2 hr.

3. Firestop System — The firestop system shall consist of the following:

A. Packing Material — Min 4 in. (102 mm) thickness of 4 pcf (64 kg/m³) mineral wool batt insulation tightly packed into the opening as a permanent form. Packing material to be recessed from top surface of floor or both surfaces of wall to accommodate the required thickness of fill material.

B. Fill, Void or Cavity Material - Sealant* — Min 1/2 in. (13 mm) thickness of fill material applied within the annulus flush with the top surface of the floor or both surfaces of the wall.

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — FS-ONE MAX Intumescent Sealant.

++Bearing the UL Listing Mark

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



Hilti Firestop Systems

Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
November 10, 2022