

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20131115-R13240  
**Report Reference** R13240  
**Issue Date** 2013-November-15

**Issued to:** Hilti Construction Chemicals, Div of Hilti Inc.  
5400 S 122<sup>nd</sup> East Ave  
Tulsa, OK 74146

**This is to certify that  
representative samples of**


Fill, Void or Cavity Materials  
Fill, Void or Cavity Materials Certified for Canada  
CFS-S SIL GG and CFS-S SIL SL for use in Through-  
Penetration Firestop and Joint Systems in the UL Fire  
Resistance Directory and in the Products Certified for  
Canada Directory.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** ANSI/UL 1479, "Fire Tests of Through-Penetration  
Firestops," – Edition 3 – Revision Date 2012/10/19  
ANSI/UL 2079, "Tests for Fire Resistance of Building Joint  
Systems," – Edition 4 – Revision Date 2012/12/12  
CAN/ULC-S115, "Standard Method of Fire Tests of Firestop  
Systems." – Edition 4 – Issue Date 2011/06/01

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Classification Mark should be considered as being covered by  
UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle: with the word "CLASSIFIED"  (as shown); a control  
number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of  
the product; and the product category name (product identity) as indicated in the appropriate UL  
Directory.

Look for the UL Classification Mark on the product.



William R. Carney, Director, North American Certification Programs

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

