



Classified by
Underwriters Laboratories, Inc.
to CAN/ULC-S115

System No. W-J-0024

F Rating - 1 and 2 Hr (See Items 1 and 2)


FT Rating - 1 and 2 Hr (See Item 2)

FH Rating - 0 Hr

FTH Rating - 0 Hr



WJ0024



1. Wall Assembly — Min 121 mm and 152 mm (4-3/4 in. and 6 in.) thick reinforced lightweight or normal weight (1600-2400 kg/m³ or 100-150 pcf) concrete for 1 and 2 hr fire rated walls, respectively. Wall may also be constructed of any solid or filled UL Classified Concrete Blocks*. Max area of opening is 2903 cm² (450 in²) with max dimension of 762 mm (30 in.).

See Concrete Blocks (CAZT) category in the Fire Resistance Directory for names of manufacturers.

2. Fill, Void or Cavity Materials* — Foam Fill material applied within annulus flush with one surface of the wall. Min fill material thickness for 1 hr F and T Ratings is 121 mm (4-3/4 in.). Min fill material thickness for 2 hr F and T Ratings is 152 mm (6 in.).

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC — CP 660 Firestop Foam

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.



Hilti Firestop Systems

Reproduced by HILTI, Inc. Courtesy of
Underwriters Laboratories, Inc.
January 25, 2016