

Schedule of joint firestop systems. Basis of Design: Hilti, Inc.

JOINT TYPE	F-RATING (HR)	BASIS OF DESIGN cUL SYSTEM	
		JOINT WIDTH LESS THAN OR EQUAL TO 2"	JOINT WIDTH GREATER THAN 2", LESS THAN OR EQUAL TO 6" ⁴
CONCRETE (FLOOR-TO-FLOOR)	1	FF-D-1012, FF-D-1013 ¹	FF-D-1012, FF-D-1013
	2	FF-D-1012, FF-D-1013 ¹	FF-D-1012, FF-D-1013
	3	FF-D-1011, FF-D-1026 ¹	FF-D-1011, FF-D-1026
	4	FF-D-1047	FF-D-1125
CONCRETE (EDGE OF FLOOR SLAB-TO-WALL)	1	FW-D-1011, FW-D-1012, FW-D-1013	FW-D-1011, FW-D-1012, FW-D-1013, FW-D-1021
	2	FW-D-1011, FW-D-1012, FW-D-1013	FW-D-1011, FW-D-1012, FW-D-1013, FW-D-1021
	3	FW-D-1011	FW-D-1011, FW-D-1021
	4	FW-D-1047	FW-D-1092
CONCRETE OR BLOCK WALL TO FLAT CONCRETE FLOOR (TOP-OF-WALL)	1	N/A**	N/A**
	2	HW-D-0097 ¹	HW-D-1009
	3	HW-D-1008 ¹ , HW-D 0268	HW-D-1008
	4	HW-D-1042	HW-D-1103
CONCRETE OR BLOCK WALL TO CONCRETE OVER FLUTED METAL DECK (TOP-OF-WALL)	1	HW-D-0098	N/A**
	2	HW-D-0080, HW-D-0081, HW-D-0098	HW-D-1037
	3	N/A**	N/A**
	4	HW-D-0294	N/A**
GYPSUM WALL TO FLAT CONCRETE FLOOR (TOP-OF-WALL)	1	HW-D-0757, HW-D-0082, HW-D-0083, HW-D-0106, HW-D-0119	HW-D-1011, HW-D-1012, HW-1020
	2	HW-D-0757, HW-D-0082, HW-D-0083, HW-D-0106, HW-D-0119	HW-D-1011, HW-D-1012, HW-1020
	3	HW-D-0119	HW-D-1011, HW-D-1012, HW-1020
GYPSUM SHAFT WALL TO TOP-OF-WALL	2	HW-D-0342 (FLAT CONCRETE) HW-D-0541, HW-D-0542 (CONCRETE OVER METAL DECK)	N/A**
GYPSUM SHAFT WALL TO CONCRETE FLOOR (BOTTOM-OF-WALL)	1	BW-S-0023	N/A**
	2	BW-S-0023	N/A**
GYPSUM WALL TO CONCRETE FLOOR (BOTTOM-OF-WALL)	1	BW-S-0001, BW-S-0002, BW-S-0039	N/A**
	2	BW-S-0001, BW-S-0002, BW-S-0039	N/A**
GYPSUM WALL TO CONCRETE OVER FLUTED METAL DECK (TOP-OF-WALL)	1	HW-D-0042*, HW-D-0049*, HW-D-0087*, HW-D-0089*, HW-D-0045, HW-D-0046*, HW-D-0076*, HW-D-0077*, HW-D-0154, HW-D-0184*, HW-D-0292, HW-D-0295, HW-D-538*	HWD-1011, HWD-1012, HW-1020
	2	HW-D-0042*, HW-D-0049*, HW-D-0087*, HW-D-0089*, HW-D-0045, HW-D-0046*, HW-D-0076*, HW-D-0077*, HW-D-0154, HW-D-0184*, HW-D-292, HW-D-0295, HW-D0538*	HW-D-1011, HW-D-1012, HW-D-1020
	3	HW-D-0292, HW-D-0295	HWD-1011, HWD-1012, HW-1020
	4	HW-D-0292, HW-D-0295	N/A**
CONCRETE (WALL TO WALL)	2	WW-D-0017, WW-D-0082	WW-D-1080, WW-D-1084
	3	WW-D-1011 ¹ , WW-D-0032	WW-D-1011
	4	WW-D-1047	WW-D-1128
GYPSUM TO CONCRETE (WALL TO WALL)	1	WW-D-0040	N/A**
	2	WW-D-0040	N/A**

* SEE NOTE 3

** CONTACT HILTI FOR CURRENT cUL-CLASSIFIED SYSTEM OR ENGINEERING JUDGMENT DRAWING: 800-363-4458

NOTES:

1. CLASSIFIED SYSTEMS FOR 2" - 6" WIDE JOINTS MAY BE USED FOR JOINTS 2" WIDE AND LESS.
2. CONFIRM THAT MOVEMENT CAPABILITIES OF THE SELECTED cUL SYSTEM MEETS OR EXCEEDS THE SPECIFIED MOVEMENT RANGE OF THE Particular JOINT.
3. SYSTEMS MARKED WITH ASTERIK (*) ARE SUITABLE FOR TOP-OF-WALL JOINTS WHERE THE FLUTED METAL DECK HAS SPRAY-ON MONOKOTE MK-6/HY FIREPROOFING.
4. VERIFY ALLOWABLE JOINT WIDTH ON SPECIFIC cUL SYSTEM DRAWING.