



Hilti North America  
7250 Dallas Parkway Ste. 1000  
Plano, TX 75024  
800-879-8000

**April 26<sup>th</sup>, 2022**

**CP 506 Smoke & Acoustical Sealant Performance Evaluations**

To Whom It May Concern:

This letter is to confirm that the following material have been tested/evaluated as noted with the listed standards by Hilti, Inc:

**Product:** CP 506 smoke and acoustic sealant

**Performance Criteria**

- ASTM C834
- ASTM C919
- ASTM D217
- ASTM E84
- ASTM E90
- ASTM G21
- ISO 11600 12.5% movement

Additionally, CP 506 remains flexible and adhesive after 500 hours of accelerated weathering as specified in ASTM C734, is non-sagging and non-staining.

Please refer to [www.us.hilti.com](http://www.us.hilti.com) for additional product details.

Best regards,

**Joshua Close**

Marketing | Product Manager – Fire Protection  
M 972-214-9144  
E [joshua.close@hilti.com](mailto:joshua.close@hilti.com)

**Hilti North America**  
7250 Dallas Parkway Ste. 1000  
Plano TX 75024  
1-800-879-8000  
[www.hilti.com](http://www.hilti.com)