

RESIDENTIAL HOLLOW CORE Floor Substrate: Hollow core concrete slab			
SHEET	MEP PENETRATIONS THRU	SYSTEM	DESCRIPTION
6.1	FLOORS > 5" THICK	F-B-1029	METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (3-HR)
		F-B-5005	INSULATED (AB/PVC & GLASS FIBER) METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (3-HR)
6.2	FLOORS OR WALLS ≤ 5" THICK	C-A-J-1226	METAL PIPE THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-1513	MULTIPLE METAL PIPE THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-2035	PLASTIC PIPE THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-2079	PLASTIC PIPE THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-3283	CABLE BUNDLE THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-5090	METAL PIPE WITH AB/PVC INSULATION THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-5091	METAL PIPE WITH GLASS FIBER OR CALCIUM SILICATE INSULATION THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-6042	ELECTRICAL BUSWAY THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-7051	METAL DUCT (WITHOUT DAMPER) THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-7084	ROUND SHEET METAL DUCT THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-7145	SHEET METAL DUCT WITH GLASS FIBER INSULATION THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-J-8099	MULTIPLE PENETRATIONS THROUGH CONCRETE OR MASONRY (2-HR)
		C-B-J-1045	METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2-HR)
		C-B-J-1046	METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2-HR)
6.3	FLOORS OR WALLS > 5" THICK	C-B-J-1059	MULTIPLE METALLIC PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (3-HR)
		C-B-J-3024	CABLE BUNDLE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2-HR)
		C-B-J-5013	INSULATED (GLASS FIBER) METAL PIPE THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (2-HR)
		C-B-J-7005	METAL DUCT THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (3-HR)
		C-B-J-8027	HVAC LINE SET THROUGH HOLLOW-CORE CONCRETE FLOOR ASSEMBLY (3-HR)
		W-L-1054	METAL PIPE THROUGH GYPSUM WALL ASSEMBLY (1-HR)
6.4	GYPSUM WALL	W-L-1389	MULTIPLE METAL PIPES THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-2028	PLASTIC PIPE THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-3334	CABLE BUNDLE THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-3414	CABLE THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-5028	METAL PIPE WITH AB/PVC INSULATION THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-5029	METAL PIPE WITH GLASS FIBER OR CALCIUM SILICATE INSULATION THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-7042	METAL DUCT (WITHOUT DAMPER) THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-7155	METAL DUCT THROUGH GYPSUM WALL ASSEMBLY
		W-L-7156	METAL DUCT WITH GLASS FIBER INSULATION THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-J-3216	CABLE BUNDLE (1") (2-HR)
6.5	CONCRETE OR BLOCK WALL	CLIV OR CLIV 76	MEMBRANE PENETRATION IN GYPSUM WALL ASSEMBLY (2-HR)
6.6	MEMBRANE PENETRATION		

SHEET	JOINTS	SYSTEM	DESCRIPTION
6.7	GYPSUM WALL	BW-S-0002	BOTTOM OF WALL JOINT (2-HR)
		HW-D-0106	TOP OF WALL JOINT (2-HR)
6.8	GYPSUM SHAFT WALL	HW-D-0209	TOP OF WALL JOINT (2-HR)
		HW-D-0757	TOP OF WALL JOINT (2-HR)
6.9	GYPSUM CHASE WALL	HW-D-0342	TOP OF WALL JOINT (2-HR)
		HW-D-0572	TOP OF WALL JOINT (2-HR)
6.10	CONCRETE OR MASONRY WALL	HW-D-0758	TOP OF WALL JOINT: GYPSUM CHASE WALL ASSEMBLY (2-HR)
		HW-D-0288	TOP OF WALL JOINT: CONCRETE WALL OR MASONRY WALL ASSEMBLY (2-HR)
		HW-D-0403	TOP OF WALL JOINT: CONCRETE WALL OR MASONRY WALL ASSEMBLY (2-HR)

UL FIRE RESISTANCE DIRECTORY NOMENCLATURE

Through Penetrations

First letter represents what is being penetrated	Second letter(s) provide more information about the floor or wall:	Four digit number describes the penetrating item(s)	Example: CAJ1150
F = FLOOR W = WALLS C = FLOORS OR WALLS (COMBINED)	A = CONCRETE FLOORS WITH A MINIMUM THICKNESS LESS THAN OR EQUAL TO 5 IN B = CONCRETE FLOORS WITH A MINIMUM THICKNESS GREATER THAN 5 IN C = FRAMED FLOORS E = FOR-CEILING ASSEMBLIES CONSISTING OF CONCRETE WITH MEMBRANE PROTECTION J = CONCRETE OR MASONRY WALLS WITH A MINIMUM THICKNESS LESS THAN OR EQUAL TO 8 IN L = FRAMED WALLS	0000 - 0999 BLANK OPENINGS 1000 - 1999 METAL PIPE, CONDUIT OR TUBING 2000 - 2999 NON METALLIC PIPE CONDUIT OR TUBING 3000 - 3999 CABLES 4000 - 4999 CABLE TRAYS 5000 - 5999 INSULATED PIPES 6000 - 6999 MISCELLANEOUS ELECTRICAL (BUSWAY) 7000 - 7999 MISCELLANEOUS MECHANICAL 8000 - 8999 MIXED PENETRATING ITEMS 9000 - 9999 RESERVED FOR FUTURE USE	C = FLOOR OR WALLPENETRATION A = CONCRETE FLOORS 5" OR LESS J = CONCRETE OR MASONRY WALLS 8" OR LESS 1150 = METAL PIPE, CONDUIT OR TUBING

Joint Systems

First letters identify the type of joint:	Second letter(s) provide more information about the floor or wall:	Four digit number describes the penetrating item(s)	Example: HWD0757
CJ = CONTINUITY HEAD OF WALL FF = FLOOR TO FLOOR WW = WALL TO WALL FW = FLOOR TO WALL HW = HEAD TO WALL BW = BOTTOM OF WALL	S = NO MOVEMENT (STATIC) D = ALLOWS MOVEMENT (DYNAMIC)	0000 - 0999 LESS THAN OR EQUAL TO 2" 1000 - 1999 GREATER THAN 2" AND LESS THAN OR EQUAL TO 6" 2000 - 2999 GREATER THAN 6" AND LESS THAN OR EQUAL TO 12" 3000 - 3999 GREATER THAN 12" AND LESS THAN OR EQUAL TO 24" 4000 - 4999 GREATER THAN 24"	HW = HEAD TO WALL D = ALLOWS MOVEMENT (DYNAMIC) 0757 = LESS THAN OR EQUAL TO 2"

Notes:

1. Refer to the following specifications for firestopping.
 - a. 07 84 00 Firestopping
 - b. 07 84 13 Penetration Firestopping
 - c. 07 84 43 Joints Firestopping
 - d. 22 00 00 Plumbing
 - e. 23 00 00 HVAC
 - f. 26 00 00 Electrical
 - g. 27 05 37 Communication Systems

For Quality Control requirements, refer to the Quality Control portion of the specification.

2. Details shown are typical details. Always refer to the listed system detail for complete system requirements. If field conditions do not match requirements of details, approved alternate details shall be utilized. Design requirements, field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - * Fire Rating (F-Rating)
 - * Temperature Rating (T-Rating)
 - * Leakage Rating (L-Rating)
 - * Water Rating (W-Rating)
 - * Annular Space
 - * Percent Fill
 - * Movement
 - * Type and thickness of fire-rated construction.

3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable subject to approval by the Authority Having Jurisdiction (AHJ). Contact Hilti Inc. for alternative systems or Engineering Judgment (800-879-8000). Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

4. References:
 - * 2017 Underwriter's Laboratories Fire Resistance Directory, Volumes 1 & 2.
 - * NFPA 101 Life Safety Code
 - * NFPA 70 – National Electric Code
 - * All governing local and regional building codes.

5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479) tested assemblies that provide a fire rating equal or greater to that of construction being penetrated.

6. All rated through-penetration assemblies shall be prominently labeled with a Hilti Firestop Label equipped with a QR code with the following information.
 - * Warning! - Do Not Disturb
 - * Through Penetration Firestop System
 - * UL System # * Product(s) used
 - * Hourly Rating (F-Rating)
 - * Installation Date
 - * Contractor's Name

7. For outlet boxes requiring protection, use only Wall Opening Protective Materials, category CLIV as classified by Underwriter's Laboratories, Fire Resistance Directory (Volume 1).

Current as of November 19, 2017. System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.
 2. Details shown are up to date as of February 2015.
 3. For additional information on the details, refer to the most current Underwriter's Laboratories Fire Resistance Directory (volume 2.)

JOB NUMBER: _____

DRAWN: _____

CHECKED: _____

ISSUE DATE: 06-13-2018

REVISIONS: _____

SHEET NAME: _____
Index of Drawings

SHEET NUMBER: _____

System No. W-J-3215

ANSI/UL 1479 (ASTM E814)	CANULC 5115	F Rating — 2 hr
L Rating at Ambient — Less than 1 CFM/Opening	FTH Rating — 1/2 and 2 hr (See Item 2)	FT Rating — 2 hr
L Rating at 400°F — Less than 1 CFM/Opening	FTH Rating — 1/2 and 2 hr (See Item 2)	FT Rating — 2 hr
L Rating at Ambient — Less than 1 CFM/Opening	FTH Rating — 1/2 and 2 hr (See Item 2)	FT Rating — 2 hr
L Rating at 400°F — Less than 1 CFM/Opening	FTH Rating — 1/2 and 2 hr (See Item 2)	FT Rating — 2 hr

SECTION A-A

Hilti Firestop Systems

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. October 16, 2015

Page 1 of 2

System No. W-J-3215

1. Wall Assembly — Min 6 in. (152 mm) thick lightweight or normal weight (150-150 pcf or 1600-2400 kg/m³) concrete. Wall may also be constructed of any UL Classified Concrete Block*. Opening may be round, rectangular or irregular with a max diam or dimension of 1 in. (25 mm).

2. See Concrete Blocks (CAZT) category in the Fire Resistance Directory for names of manufacturers.

3. Cable — Single or split bundle of cables to be installed within the opening. Aggregate cross-sectional area of cables in opening to have a residual of min 7% to max 10%. The annular space between the cable bundle and the periphery of the opening to be min 0 in. (joint contact). Cables to be rigidly supported on both sides of the wall assembly. Any combination of the following types and sizes of cables may be used:

A. Max 3C No. 8 AWG 90 copper conductor cable (Belden) with PVC insulation and jacket

B. Max 12 No. 12 AWG 90 copper conductor control cable with PVC or PLF insulation and jacket

C. Max 100 pair No. 24 AWG (or smaller) copper conductor telecommunication cable with PVC or plenum rated insulation and jacketing

D. Max 4 No. 22 AWG (or smaller) Cat 5e copper cables with PVC or plenum rated insulation and jacketing

E. Type R/UL Classified cable with Ethylene Propylene or PVC insulation and jacketing having a max outside diameter of 1/4 in. (3 mm)

F. Max 24 fiber optic cable with polyimide sheath (PVC or polyethylene jacket and insulation)

G. Through penetrating module — Max two copper conductor No. 18 AWG (or smaller) Power or Non-Power Limited Fire Alarm Cable with or without a jacket under a single entry.

H. Maximum 3C No. 10 AWG metal-clad cable.

The Hours, FT, and FTH Ratings of the firestop system are 2 hr except that for cable type B) and C), the ratings are 1/2 hr. For blank openings with no penetrations, the F, FT, FTH and FTH Ratings are 2 hr.

3. Fit, Void or Cavity Sealant* — Min 1/8 in. (3 mm) thick solid, non-foaming, non-abrasive. Paper backing of disc to be removed and disc firmly pressed around the cable bundle tapping from 5 mm into cavity to completely cover opening and firmly pressed to lap onto the wall around perimeter of opening. Disc must be firmly pressed and sealed tight. Disc to be installed at both surfaces of wall.

HILTI CONSTRUCTION CHEMICALS, DIV OF HILTI INC. — CFS-D 1 Firestop Cable Disc

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

Hilti Firestop Systems

Reproduced by Hilti, Inc. Courtesy of Underwriters Laboratories, Inc. October 16, 2015

Page 2 of 2

Notes:

1. Refer to the following specifications for firestopping.
 - a. 07 84 00 Firestopping
 - b. 07 84 13 Penetration Firestopping
 - c. 07 84 43 Joints Firestopping
 - d. 22 00 00 Plumbing
 - e. 23 00 00 HVAC
 - f. 26 00 00 Electrical
 - g. 27 05 37 Communication Systems

For Quality Control requirements, refer to the Quality Control portion of the specification.

2. Details shown are typical details. Always refer to the listed system detail for complete system requirements. If field conditions do not match requirements of details, approved alternate details shall be utilized. Design requirements, field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - * Fire Rating (F-Rating)
 - * Temperature Rating (T-Rating)
 - * Leakage Rating (L-Rating)
 - * Water Rating (W-Rating)
 - * Annular Space
 - * Percent Fill
 - * Movement
 - * Type and thickness of fire-rated construction.

3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable subject to approval by the Authority Having Jurisdiction (AHJ). Contact Hilti Inc. for alternative systems or Engineering Judgment (800-879-8000). Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

4. References:
 - * 2017 Underwriter's Laboratories Fire Resistance Directory, Volumes 1 & 2.
 - * NFPA 101 Life Safety Code
 - * NFPA 70 – National Electric Code
 - * All governing local and regional building codes.

5. Firestop System installation must meet requirements of ASTM E-814 (UL 1479) tested assemblies that provide a fire rating equal or greater to that of construction being penetrated.

6. All rated through-penetration assemblies shall be prominently labeled with a Hilti Firestop Label equipped with a QR code with the following information.
 - * Warning! - Do Not Disturb Through Penetration Firestop System
 - * UL System # * Product(s) used
 - * Hourly Rating (F-Rating)
 - * Installation Date
 - * Contractor's Name

7. For outlet boxes requiring protection, use only Wall Opening Protective Materials, category CLIV as classified by Underwriter's Laboratories, Fire Resistance Directory (Volume 1).

Current as of November 19, 2017. System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.
 2. Details shown are up to date as of February 2015.
 3. For additional information on the details, refer to the most current Underwriter's Laboratories Fire Resistance Directory (volume 2.)

JOB NUMBER: _____

DRAWN: _____

CHECKED: _____

ISSUE DATE: 06-13-2018

REVISIONS: _____

SHEET NAME:
Residential - Hollow Core - Concrete or Block Wall

SHEET NUMBER: _____

System No. HW-D-0342

ANSI/L2019	CANULC S115
Assembly Rating — 2 1/2 hr	F Rating — 2 hr
Normal Joint Width — 1 in.	FT Rating — 2 hr
Class 1 Movement Capabilities — 0% Compression and Extension	FTI Rating — 2 hr
L Rating At Ambient — Less Than 1 CFM/in. ft	FTI Rating — 2 hr
L Rating At 400 F — Less Than 1 CFM/in. ft	Normal Joint Width — 1 in.
	Class 1 Movement Capabilities — 0% Compression and Extension
	L Rating At Ambient — Less Than 1 CFM/in. ft
	L Rating At 400 F — Less Than 1 CFM/in. ft

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. March 20, 2015. Page: 1 of 2

System No. HW-D-0342

1. Floor Assembly — Min. 2-1/2 in. (64 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete.

2. Steel Stud Assembly — The 2 1/2 hr-rated gypsum board steel stud wall assembly shall be constructed of the materials and in the manner described in the individual UL55, V400 or M400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

A. Floor and Ceiling Runners — J-shaped runner, 2-1/2 in. (64 mm) wide with unequal legs of min. 1-1/4 in. (32 mm) and 2 in. (51 mm), fabricated from min. 24 MSG galv. steel. Runners positioned with short leg toward finished side of wall. Runners attached to structural supports with steel fasteners located not greater than 24 in. (61 mm) from ends and not greater than 24 in. (61 mm) OC.

B. Light Gauge Framing — Stiffened Ceiling Track — Openwall Stiffened ceiling track shall consist of galv. steel channels with added flanges. Stiffened ceiling track used to accommodate steel "C" stud (Item 3C), attached to concrete at corners of ceiling with steel fasteners spaced max. 24 in. (61 mm) OC.

CALIFORNIA EXPANDED METAL PRODUCTS CO. — CST
 IDAHO CONSTRUCTION INNOVATIONS, INC. DSA SUBTRACK SYSTEMS — SLP-TRK
 MARIPOSA, DIV. OF HARSIS INDUSTRIES INC. — Type SLT
 B1. Light Gauge Framing Members — (Optional Steel Sheet)

For an option, the steel studs (Item 3C) may incorporate vertical deflection clips for attachment to the ceiling runner (Item 2A) in accordance with the manufacturer's instructions.

THE STEEL NETWORK INC. — WPC-20 S130

C. Steel Stud — C-shaped studs, 2-1/2 in. (64 mm) wide by 1-1/2 in. (38 mm) deep, fabricated from min. 20 MSG galv. steel, cut to lengths 28 in. (713 mm) deep from ceiling height and spaced 24 in. (61 mm) OC. Stud used in floor runner or bottom and a runner on studded ceiling track at top. After installation of gypsum board free panels (Item 2D), studs secured to flange of floor runner on finished side of wall only with No. 8 by 12 in. (13 mm) long self-drilling self-tapping wall stud steel screws as per midheight.

D. Gypsum Board — 1/2 in. (12.5 mm) thick 24 in. (61 mm) wide gypsum board free panels as specified in the individual UL55 or V400 Series design. Panels cut 1 in. (25 mm) less in length than floor to ceiling height. Vertical edges mounted in "Y" shaped section of "C" stud, at the ends of the assembly, the end edge of the end panel is finished to the top of vertical runners (Item 2B) with 1-5/8 in. (41 mm) long Type 5 steel screws spaced max. 12 in. (305 mm) OC.

E. Gypsum Board — Gypsum board sheets, 1/2 in. (12.5 mm) thick, applied vertically or horizontally in two layers on finished side of wall as specified in the individual UL55 or V400 Series design. A max. 1 in. (25 mm) gap shall be maintained between the top of the gypsum board and the bottom surface of the concrete floor. The screws attaching the gypsum board layers to the "C" stud shall be spaced 1 in. (25 mm) below the bottom of the J-runner or studded ceiling track. No gypsum board attachment screws are to penetrate the ceiling runner and studded ceiling track.

3. Joint System — Max. separation between top of free panel (Item 2D) and between top of gypsum board sheets (Item 2E) at line of installation of joint system is 1 in. (25 mm). The joint system is designed to accommodate a minimum panel compression and extension from its installed width. The joint system consists of the following:

A. TR "V" or Cavity Material — Sealant — Min. 1 in. (25 mm) depth of sealant to be installed to fill linear gap between top of gypsum board free panel (Item 2D) and top inside surface of ceiling J-runner or studded ceiling track prior to installation of gypsum board (Item 2E) on finished side of wall. Min. 1 in. (25 mm) depth of sealant to be installed to fill linear gap between top of gypsum board sheets (Item 2E) and bottom of concrete floor.

HETI CONSTRUCTION CHEMICALS, DIV. OF HETI INC. — CP-80
 *Sealing the UL Classification Mark.

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. November 20, 2015. Page: 2 of 2

System No. HW-D-0572

ANSI/L2019	CANULC S115
Assembly Rating — 1 and 2 Hr (See Item 2)	F Rating — 1 and 2 Hr (See Item 2)
Normal Joint Width — 1-1/2 in.	FT Rating — 1 and 2 Hr (See Item 2)
Class 1 Movement Capabilities — 0% Compression and Extension	FTI Rating — 1 and 2 Hr (See Item 2)
	Normal Joint Width — 1-1/2 in.
	Class 1 Movement Capabilities — 0% Compression and Extension

1. Floor Assembly — Min. 2-1/2 in. (64 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Floor may also consist of any fire-rated UL Classified hollow-core Precast Concrete Deck.*

See Physical Constraints (C&T) category in the Fire Resistance Directory for names of manufacturers.

2. Steel Stud Assembly — The 1 hr or 2 hr-rated gypsum board steel stud wall assembly shall be constructed of the materials and in the manner described in the individual UL55, V400 or M400 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

A. Floor and Ceiling Runners — J-shaped runner, steel sheet or wall to steel studs (Item 3C) with unequal legs of 1 in. (25 mm) and 2 in. (51 mm), fabricated from 24 MSG galv. steel. Runners positioned with short leg toward finished side of wall. Runners attached to steel wall fasteners located not greater than 2 in. (51 mm) from ends and not greater than 24 in. (61 mm) OC.

B. Ceiling Runner — Ceiling runner shall consist of galv. steel channel used to accommodate steel studs (Item 3C). Flange height of ceiling runner shall be min. 1-1/2 in. (38 mm) greater than max. extended joint width. Ceiling runner secured with steel fasteners located not more than 2 in. (51 mm) from ends and spaced not greater than 24 in. (61 mm) OC.

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. November 20, 2015. Page: 1 of 2

System No. HW-D-0572

B1. Light Gauge Framing* — Stiffened Ceiling Runner — As an alternate to the ceiling runner in Item 2B, stiffened ceiling runner to consist of galv. steel channel with stiffened flanges used to accommodate steel studs (Item 3C). Flange height of stiffened ceiling runner shall be min. 1-1/2 in. (38 mm) greater than max. extended joint width. Stiffened ceiling runner secured with steel fasteners located not more than 2 in. (51 mm) from ends and spaced max. 24 in. (61 mm) OC.

IDAHO CONSTRUCTION INNOVATIONS, INC. DSA SUBTRACK SYSTEMS — SLP-TRK
 CALIFORNIA EXPANDED METAL PRODUCTS CO. — CST
 CLARKBROOK BUILDING SYSTEMS — Type SLT SLP-TRK
 MARIPOSA, DIV. OF HARSIS INDUSTRIES INC. — Type SLT METAL-LITE INC. — The System

SCAFCO STEEL STUD MANUFACTURING CO. — Studded Track
 TELLURIDE INDUSTRIES L.L.C. — True-Action Studded Track

C. Steel Stud — C-shaped studs, min. 2 in. (51 mm) wide by 1-1/2 in. (38 mm) deep, fabricated from 20 MSG galv. steel, cut to lengths 34 in. (863 mm) deep from floor to ceiling height and spaced 24 in. (61 mm) OC.

D. Gypsum Board — Item 1 in. (25 mm) thick gypsum board free panels. Panels cut 1-1/2 in. (38 mm) less in length than floor to ceiling height. Vertical edges mounted in finished section of "C" stud. At the ends of the assembly, the free edge of the end panels are attached to the long leg vertical runners (Item 2A) with 1-5/8 in. (41 mm) long Type 5 steel screws spaced max. 12 in. (305 mm) OC.

E. Gypsum Board — Item 1/2 in. (12.5 mm) thick gypsum board applied vertically in one or two layers for 1 hr and 2 hr fire-rated assemblies, respectively. Panels cut 1-1/2 in. (38 mm) less in length than floor to ceiling height. The screws attaching the gypsum board layers to the "C" stud shall be located 1 in. (25 mm) below the bottom of the ceiling runner or studded ceiling track. No gypsum board attachment screws are to penetrate the ceiling runner or studded ceiling track.

The height of edge of the joint system is equal to the height of the edge of the wall.

3. Joint System — Max. separation between bottom of floor and top of gypsum board of the area of installation of the joint system is 1/2 in. (13 mm). The joint system is designed to accommodate a min. 50 percent compression or extension from its installed width. The joint system consists of the following:

A. Forming Material* — Min. 1/2 in. (13 mm) thick mineral wool batt insulation cut to a thickness twice larger than the distance between the top of the gypsum board and the bottom of the floor. Material compressed 50 percent and installed with ceiling runner above top of free panel flush with the inside surface of the panel. Material compressed and installed on finished side of the wall between the top of the gypsum board and the bottom of the floor. Flush with the surface of the wall.

ROCK WOOL MANUFACTURING CO. — Deka Board
 ROCK, INC. — SAFE

THE WAREHOUSE INC. — Type SFP

A1. Forming Material* — Slips — As an alternate to Item 2A, the slips are slanted to a height twice larger than the distance between the top of the gypsum board and the bottom of the floor. Slips compressed 50 percent and installed with ceiling runner above top of free panel flush with the inside surface of the panel. Slips compressed and installed on finished side of the wall between the top of the gypsum board and the bottom of the floor. Flush with the surface of the wall.

HETI CONSTRUCTION CHEMICALS, DIV. OF HETI INC. — CP 787 Speed Slips

B. TR "V" or Cavity Material* — Min. 1/2 in. (13 mm) depth of sealant to be installed to fill linear gap between top of gypsum board free panel and on finished side of the stud wall to completely cover mineral wool forming material. Fill material to overlap a min. of 1/2 in. (13 mm) onto gypsum board and ceiling runner without stud cavity. Fill material to overlap a min. of 1/2 in. (13 mm) onto gypsum board and concrete on finished side of wall.

HETI CONSTRUCTION CHEMICALS, DIV. OF HETI INC. — CP-872 Firestop Spray or CFS-SP WB Firestop Joint Spray

*Indicates such products shall bear the UL or UL Certification Mark for jurisdictions employing the UL or UL Certification (such as Canada), respectively.

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. November 20, 2015. Page: 2 of 2

Notes:

- Refer to section 07840 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
- Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - Minimum and maximum Width of Joints
 - Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
- If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
- References:
 - 2017 Underwriter's Laboratories Fire Resistance Directory, Volume 2
 - Intertek Directory of Building Products
 - All governing local and regional building codes

Current as of November 19, 2017. System details subject to change without notice.

Notes to designer (delete this note after reading and replace with title block information)

- Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.
- Details shown are up to date as of February 2015.
- For additional information on the details, refer to the most current Underwriter's Laboratories Fire Resistance Directory (volume 2.)

JOB NUMBER: _____

DRAWN: _____

CHECKED: _____

ISSUE DATE: 06-13-2018

REVISIONS: _____

SHEET NAME: Residential - Hollow Core - Gypsum Shaft Wall

SHEET NUMBER: _____

System No. HW-D-0758

ANSI A207.9	CANULC 5115
Assembly Rating — 1 and 2 hr (See Item 2)	F Rating — 1 and 2 hr (See Item 2)
Normal Joint Width — 1/2 to 3/8 in. (See Item 3)	FT Rating — 1 and 2 hr (See Item 2)
Class I or II Movement Capabilities — 50% Compression or Extension or 80% Compression Only	FN Rating — 1 and 2 hr (See Item 2)
	FTN Rating — 1 and 2 hr (See Item 2)
L Rating at 400° F — Less than 1 CFM/Lin Ft	Normal Joint Width — 1/2 to 3/8 in. (See Item 3)
	Class I or II Movement Capabilities — 50% Compression or Extension or 80% Compression Only
	L Rating at Ambient — Less than 1.55 L/Lin Ft
	L Rating at 400° F — Less than 1.55 L/Lin Ft

UL
Underwriters Laboratories, Inc.
Hitt Firestop Systems

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. December 31, 2015

Page 1 of 2

System No. HW-D-0758

1. Floor Assembly — Min. 4-1/2 in. (114 mm) thick reinforced (lightweight or normal weight) (100-150 pcf or 1600-2400 kg/m³) structural concrete. Floor may also be constructed of any 4 in. (102 mm) thick, U.C. Classified Hollowcore Precast Concrete Unit*.

2. Wall Assembly — The 1/2 to 3/8 in. (12.7 to 9.5 mm) gasket must be installed in the individual UAWD, VAWD or VWCD Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:

A. Steel Floor and Ceiling Runners — Floor and ceiling runners of wall assembly shall consist of min. No. 20 gauge galv-steel channels sized to accommodate steel studs (See 2B). Flange height of ceiling runner shall be min. 1 1/2 in. (38 mm) greater than max. extended joint width. Ceiling runner secured to concrete floor slab with steel masonry anchors, steel fasteners spaced 24 in. (610 mm) OC.

A1. Light Gauge Framing* — Stacked Ceiling Runner — As an alternate to the ceiling runner in Item 2A, install ceiling runner to consist of galv-steel channel with angled flanges secured to accommodate steel studs (See 2B). Stacked ceiling runner secured to concrete floor slab with steel masonry anchors and steel fasteners spaced 24 in. (610 mm) OC.

A2. Light Gauge Framing* — Notched Ceiling Runner — As an alternate to the ceiling runner in Item 2A through 2A3, notched ceiling runner to consist of galv-steel channel with notched flanges secured to accommodate steel studs (See 2B). Notched ceiling runner secured to concrete floor slab with steel masonry anchors or steel fasteners spaced max. 24 in. (610 mm) OC.

A3. Light Gauge Framing* — Notched Ceiling Runner — As an alternate to the ceiling runner in Item 2A through 2A3, notched ceiling runner to consist of galv-steel channel with notched flanges secured to accommodate steel studs (See 2B). Notched ceiling runner secured to concrete floor slab with steel masonry anchors or steel fasteners spaced max. 24 in. (610 mm) OC.

CALMEX SUPPLY, INC. — Type S&T.

B. Studs — Steel studs to be min. 3-1/2 in. (89 mm) wide and formed of min. 25 galv-steel. Studs cut 24 in. (610 mm) to 19 in. (483 mm) less in length than assembly height with bottom flange in wall secured to floor runner. Steel studs installed in ceiling runner without attachment. Studs spaced max. 24 in. (610 mm) OC.

C. Gypsum Board* — Gypsum board 1/2 in. (12.7 mm) thick applied on both sides of wall as specified in the individual Wall and Partition Design except that a max. 3/8 in. (9.5 mm) gap shall be maintained between the top of the gypsum board and the bottom of the floor assembly. The screws attaching the gypsum board to stud at the top of the wall shall be located 1 in. (25 mm) to 1-1/2 in. (38 mm) below the bottom edge of the ceiling runner. No gypsum board attachment screws shall be driven into the ceiling runner.

The finish surface of the joint system is equal to the finish of the wall.

3. Fire, Void or Core Material* — Top Track Seal — When min. separation between the bottom of floor and top of wall is 1/2 in. (13 mm), the joint system is designed to accommodate a max. 25 percent compression or extension from its installed width. When max. separation between the bottom of floor and top of wall is 3/8 in. (9.5 mm), the joint system is designed to accommodate a max. 60% compression only from its installed width. Fastener installed from wall installed over the ceiling runner (See 2B) prior to attachment to underside of concrete floor in accordance with the installation instructions.

HETI CONSTRUCTION CHEMICALS, DIV OF HETI, INC. — CFS-TTS 306, CFS-TTS 600 or CFS-TTS 605

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

UL
Underwriters Laboratories, Inc.
Hitt Firestop Systems

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. December 31, 2015

Page 2 of 2

Notes:

1. Refer to section 07840 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 - * Minimum and maximum Width of Joints
 - * Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
 - * 2017 Underwriter's Laboratories Fire Resistance Directory, Volume 2
 - * Intertek Directory of Building Products
 - * All governing local and regional building codes

Current as of November 19, 2017.
System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.
 2. Details shown are up to date as of February 2015.
 3. For additional information on the details, refer to the most current 'Underwriter's Laboratories Fire Resistance Directory (volume 2.)'

JOB NUMBER: _____

DRAWN: _____

CHECKED: _____

ISSUE DATE: 06-13-2018

REVISIONS: _____

SHEET NAME:
Residential - Hollow Core - Gypsum Chase Wall

SHEET NUMBER: _____

System No. HW-D-0268
Assembly Rating - 3 Hr
Nominal Joint Width - 1 in.
L Rating At Ambient - Less Than 1 CFM/Lin Ft
L Rating At 400°F - Less Than 1 CFM/Lin Ft
Class II Movement Capabilities - 12.5% Compression and Extension

1. Floor Assembly — Min 2-1/2 in. (64 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete.
 Floor may also be constructed of any min. 8 in. (203 mm) thick, UL Classified Hollowcore Precast Concrete Unit*.
 See Precast Concrete Units (PCU) category in the Fire Resistance Directory for names of manufacturers.
 2. Wall Assembly — Min 8 in. (203 mm) thick clear reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete.
 Wall may also be constructed of any UL Classified Concrete Block*.
 See Concrete Blocks (CB) category in the Fire Resistance Directory for names of manufacturers.
 3. Joint System — Max separation between bottom of floor assembly and top of concrete wall at time of installation is 1 in. (25 mm). The joint system is designed to accommodate a max. 12.5 percent compression or extension from its installed width.
 4. Forming Material — (Optional, Not Shown) — Mineral wool insulation or polystyrene foam backup rod. Forming material to be recessed from both surfaces of the wall as required to accommodate the required thickness of fill material.
 A. 1/2" "Jot or Cavity Material" — Sealant — A 1/2 in. (13 mm) thickness of fill material installed within the joint, flush with each surface of the wall.
 B. 1/2" "Jot or Cavity Material" — Sealant — Min. 1/2 in. (13 mm) thickness of fill material applied within the joint, flush with both surfaces of the wall.
 HETI CONSTRUCTION CHEMICALS, DIV OF HETI, INC. — CP868 Flexible Firestop Sealant
 *Bearing the UL Classification Mark

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. June 26, 2008

System No. HW-D-0403
Assembly Rating - 3 Hr
L Rating at Ambient - Less than 1 CFM/Lin Ft
L Rating at 400°F - Less than 1 CFM/Lin Ft
Nominal Joint Width - 2 in.
Class II Movement Capabilities - 8% Compression Or Extension

1. Floor Assembly — Min 8 in. (203 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete.
 2. Wall Assembly — Min 8 in. (203 mm) thick reinforced lightweight or normal weight (100-150 pcf or 1600-2400 kg/m³) structural concrete. Wall may also be constructed of any UL Classified Concrete Block*.
 See Concrete Blocks (CB) category in the Fire Resistance Directory for names of manufacturers.
 3. Joint System — Max separation between bottom of floor and top of wall (at time of installation of joint system) is 2 in. (51 mm). The joint system is designed to accommodate a max. 8 percent compression or extension from its installed width.
 4. Forming Material — Min 4 pcf (64 kg/m³) mineral wool batt insulation installed in joint opening as a permanent form. Pieces of batt cut to min. width of 5 in. (127 mm) and installed edge first to joint opening, parallel with joint direction. Each batt section is compressed to 50 percent in thickness and such that the compressed batt sections are recessed from both surfaces of the wall as required to accommodate the required thickness of fill material. Adjacent lengths of batt to be tightly lapped with lapped seams spaced max. 24 in. (610 mm) apart along the length of the joint.
 B. 1/2" "Jot or Cavity Material" — Sealant — Min. 1/2 in. (13 mm) thickness of fill material applied within the joint, flush with both surfaces of the wall.
 HETI CONSTRUCTION CHEMICALS, DIV OF HETI, INC. — CP868 Flexible Firestop Sealant
 *Bearing the UL Classification Mark

Reproduced by HETI, Inc. Courtesy of Underwriters Laboratories, Inc. September 20, 2002

Notes:

1. Refer to section 07840 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
 * Minimum and maximum Width of Joints
 * Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
 * 2017 Underwriter's Laboratories Fire Resistance Directory, Volume 2
 * Intertek Directory of Building Products
 * All governing local and regional building codes

*Current as of November 19, 2017.
 System details subject to change without notice.*

<Notes to designer (delete this note after reading and replace with title block information)>
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.
 2. Details shown are up to date as of February 2015.
 3. For additional information on the details, refer to the most current "Underwriter's Laboratories Fire Resistance Directory (volume 2.)"

JOB NUMBER: _____

DRAWN: _____

CHECKED: _____

ISSUE DATE: 06-13-2018

REVISIONS: _____

SHEET NAME:
 Residential - Hollow Core - Concrete or Masonry Wall

SHEET NUMBER: _____