

RESIDENTIAL - WOOD CONSTRUCTION			
Floor Substrate: Wood Floor/Ceiling Assembly			
SHEET	MEP PENETRATIONS THRU	SYSTEM	DESCRIPTION
5.1/5.2	WOOD FLOOR/ CEILING ASSEMBLY	F-C-0002	WOOD FLOOR/CEILING ASSEMBLY (2-HR)
		F-C-1009	METAL PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (2-HR)
		F-C-1059	METAL PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (2-HR)
		F-C-2009	PLASTIC PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-2010	CLOSET FLANGE THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-2011	PLASTIC PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-2418	PLASTIC PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-3012	CABLE/CABLE BUNDLE THROUGH WOOD FLOOR/CEILING ASSEMBLY (2-HR)
		F-C-5004	INSULATED (GLASS-FIBER OR AB/PVC FLEXIBLE FOAM INSULATION) METAL PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (2-HR)
		F-C-5036	INSULATED (GLASS-FIBER) METAL PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-5037	INSULATED (AB/PVC FLEXIBLE FOAM) METAL PIPE THROUGH WOOD FLOOR/CEILING ASSEMBLY (2-HR)
		F-C-7013	DUCT PENETRATION THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-7025	PENETRATION THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-7043	DUCT PENETRATION THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-8026	MULTIPLE HVAC LINE SET THROUGH WOOD FLOOR/CEILING ASSEMBLY (1-HR)
		F-C-8038	MULTIPLE PENETRATIONS THROUGH WOOD FLOOR/CEILING ASSEMBLY (2-HR)
		C-A-1226	METAL PIPE THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-1513	MULTIPLE METAL PIPES THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-2053	PLASTIC PIPE THROUGH CONCRETE OR MASONRY (2-HR)
		C-A-2079	PLASTIC PIPE THROUGH CONCRETE OR MASONRY (2-HR)
C-A-3283	CABLE BUNDLE THROUGH CONCRETE OR MASONRY (2-HR)		
C-A-5090	METAL PIPE WITH AB/PVC INSULATION THROUGH CONCRETE OR MASONRY (2-HR)		
C-A-5091	METAL PIPE WITH GLASS FIBER OR CALCIUM SILICATE INSULATION THROUGH CONCRETE OR MASONRY (2-HR)		
C-A-6042	ELECTRICAL BUSWAY THROUGH CONCRETE OR MASONRY (2-HR)		
C-A-7051	METAL DUCT (WITHOUT DAMPER) THROUGH CONCRETE OR MASONRY (2-HR)		
C-A-7084	ROUND SHEET METAL DUCT THROUGH CONCRETE OR MASONRY (2-HR)		
C-A-7145	SHEET METAL DUCT WITH GLASS FIBER INSULATION THROUGH CONCRETE OR MASONRY (2-HR)		
C-A-8099	MULTIPLE PENETRATIONS THROUGH CONCRETE OR MASONRY (2-HR)		
5.4	GYPSUM WALL	W-L-1054	METAL PIPE THROUGH GYPSUM WALL ASSEMBLY (1-HR)
		W-L-1359	MULTIPLE METAL PIPES THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-2028	PLASTIC PIPE THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-2038	PLASTIC PIPE THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-3334	CABLE BUNDLE THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-3414	CABLE THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-5028	METAL PIPE WITH AB/PVC INSULATION THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-5029	METAL PIPE WITH GLASS FIBER OR CALCIUM SILICATE INSULATION THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-7042	METAL DUCT (WITHOUT DAMPER) THROUGH GYPSUM WALL ASSEMBLY (2-HR)
		W-L-7155	METAL DUCT THROUGH GYPSUM WALL ASSEMBLY
W-L-7156	METAL DUCT WITH GLASS FIBER INSULATION THROUGH GYPSUM WALL ASSEMBLY (2-HR)		
5.5	CONCRETE OR BLOCK WALL	W-J-9215	CABLE BUNDLE (<1") (2-HR)
5.6	MEMBRANE PENETRATION	CLIV OR CLIV 76	MEMBRANE PENETRATION IN GYPSUM WALL ASSEMBLY (2-HR)

SHEET	JOINTS	SYSTEM	DESCRIPTION
5.7	GYPSUM WALL	H-W-S-0090	TOP OF WALL JOINT (1-HR)

**UL FIRE RESISTANCE DIRECTORY NOMENCLATURE**

Through Penetrations	First letter represents what is being penetrated	Second letter(s) provide more information about the floor or wall:	Four digit number describes the penetrating item(s)	Example: CAJ1150
F = FLOOR W = WALLS C = FLOORS OR WALLS (COMBINED)	A = CONCRETE FLOORS WITH A MINIMUM THICKNESS LESS THAN OR EQUAL TO 5 IN  B = CONCRETE FLOORS WITH A MINIMUM THICKNESS GREATER THAN 5 IN  C = FRAMED FLOORS  E = FOR-CEILING ASSEMBLIES CONSISTING OF CONCRETE WITH MEMBRANE PROTECTION  J = CONCRETE OR MASONRY WALLS WITH A MINIMUM THICKNESS LESS THAN OR EQUAL TO 8 IN  L = FRAMED WALLS	0000 - 0999 BLANK OPENINGS  1000 - 1999 METAL PIPE, CONDUIT OR TUBING 2000 - 2999 NON METALLIC PIPE CONDUIT OR TUBING  3000 - 3999 CABLES 4000 - 4999 CABLE TRAYS  5000 - 5999 INSULATED PIPES 6000 - 6999 MISCELLANEOUS ELECTRICAL (BUSWAY)  7000 - 7999 MISCELLANEOUS MECHANICAL 8000 - 8999 MIXED PENETRATING ITEMS 9000 - 9999 RESERVED FOR FUTURE USE	C = FLOOR OR WALLPENETRATION  A = CONCRETE FLOORS 5" OR LESS  J = CONCRETE OR MASONRY WALLS 8" OR LESS  1150 = METAL PIPE, CONDUIT OR TUBING	

Joint Systems	First letters identify the type of joint:	Second letter(s) provide more information about the floor or wall:	Four digit number describes the penetrating item(s)	Example: HWD0757
CJ = CONTINUITY HEAD OF WALL FF = FLOOR TO FLOOR WW = WALL TO WALL FW = FLOOR TO WALL HW = HEAD TO WALL BW = BOTTOM OF WALL	S = NO MOVEMENT (STATIC)  D = ALLOWS MOVEMENT (DYNAMIC)	0000 - 0999 LESS THAN OR EQUAL TO 2"  1000 - 1999 GREATER THAN 2" AND LESS THAN OR EQUAL TO 6"  2000 - 2999 GREATER THAN 6" AND LESS THAN OR EQUAL TO 12"  3000 - 3999 GREATER THAN 12" AND LESS THAN OR EQUAL TO 24"  4000 - 4999 GREATER THAN 24"	HW = HEAD TO WALL  D = ALLOWS MOVEMENT (DYNAMIC)  0757 = LESS THAN OR EQUAL TO 2"	

**Notes:**

- Refer to the following specifications for firestopping.
  - 07 84 00 Firestopping
  - 07 84 13 Penetration Firestopping
  - 07 84 43 Joints Firestopping
  - 22 00 00 Plumbing
  - 23 00 00 HVAC
  - 26 00 00 Electrical
  - 27 05 37 Communication Systems

For Quality Control requirements, refer to the Quality Control portion of the specification.

- Details shown are typical details. Always refer to the listed system detail for complete system requirements. If field conditions do not match requirements of details, approved alternate details shall be utilized. Design requirements, field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
  - Fire Rating (F-Rating)
  - Temperature Rating (T-Rating)
  - Leakage Rating (L-Rating)
  - Water Rating (W-Rating)
  - Annular Space
  - Percent Fill
  - Movement
  - Type and thickness of fire-rated construction.

If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable subject to approval by the Authority Having Jurisdiction (AHJ). Contact Hilti Inc. for alternative systems or Engineering Judgment (800-879-8000). Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.

- References:
  - 2017 Underwriter's Laboratories Fire Resistance Directory, Volumes 1 & 2.
  - NFPA 101 Life Safety Code
  - NFPA 70 – National Electric Code
  - All governing local and regional building codes.

Firestop System installation must meet requirements of ASTM E-814 (UL 1479) tested assemblies that provide a fire rating equal or greater to that of construction being penetrated.

- All rated through-penetration assemblies shall be prominently labeled with a Hilti Firestop Label equipped with a QR code with the following information.
  - Warning! - Do Not Disturb
  - Through Penetration Firestop System
  - UL System # \* Product(s) used
  - Hourly Rating (F-Rating)
  - Installation Date
  - Contractor's Name

For outlet boxes requiring protection, use only Wall Opening Protective Materials, category CLIV as classified by Underwriter's Laboratories, Fire Resistance Directory (Volume 1).

Current as of November 19, 2017. System details subject to change without notice.

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current Underwriter's Laboratories Fire Resistance Directory (volume 2)

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 06-13-2018

REVISIONS: \_\_\_\_\_

SHEET NAME: \_\_\_\_\_  
Index of Drawings

SHEET NUMBER: \_\_\_\_\_













**System No. HW-S-0090**

ANSI/UL 2079	CAW/LC 5115
Assembly Rating — 1 hr	F Rating — 1 hr
Joint Width — 1/2 in. Max.	FT Rating — 1 hr
	FH Rating — 1 hr
	FH Rating — 1 hr
	Joint Width — 1/2 in. Max.

1. Floor Assembly — The 1 in. thick solid glue, wood frame or conventional wood and steel joist floor-ceiling assembly shall be constructed of the materials and in the manner described in the individual L500 Series Floor-Ceiling Design in the UL Fire Resistance Directory and shall include the following construction features:  
 A. Flooring System — Lumber or plywood subfloor with finish floor of lumber, plywood or Floor Topping Mix™ as specified in the individual Floor-Ceiling Design.  
 B. Wood Joists — Nom 10 in. (254 mm) deep (or deeper) lumber, steel or combination lumber and steel joists, trusses or Structural Wood Members with bridging as required and with ends firestopped.  
 C. Gypsum Board — Nom 4 in. (102 mm) thick as specified in the individual Floor-Ceiling Design.  
 2. Wall Assembly — The 1 1/2 in. thick gypsum board/lumber floor wall assembly shall be constructed of the materials and in the manner described in the individual L500 Series Wall and Partition Design in the UL Fire Resistance Directory and shall include the following construction features:  
 A. Stud — Wall framing in solid stud or max 2 in. x 4 in. (51 to 102 mm) lumber spaced 16 in. (406 mm) OC. Top plate installed parallel or perpendicular to direction of wood studs and secured to bottom of joist with steel fasteners spaced max 24 in. (610 mm) OC.  
 B. Gypsum Board — Gypsum board sheets installed to meet stated thickness of 1 1/2 in. (38 mm) on each side of wall. Wall to be constructed as specified in the individual Wall and Partition Design in the UL Fire Resistance Directory, except that a max 1/2 in. (13 mm) gap shall be maintained between the top of the gypsum board and the ceiling of the floor-ceiling assembly.  
 3. Joint System — FR Void or Cavity Material™ — Sealant — Max separation between the bottom of the ceiling and the top of the wall is 1/2 in. (13 mm). Min 3/8 in. (10 mm) thickness of FR material needed to fill the joint. Seal with each surface of the wall.  
 HLT CONSTRUCTION CHEMICALS, DIV OF HLT INC — FR-GNE Sealant, CPVX Sealant or FR-GNE MAX Measurement Sealant.  
 \* Indicates each process shall meet the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

**HLT Firestop Systems**  
 Reprinted by HLT, Inc. Courtesy of Underwriters Laboratories, Inc. January 20, 2015

**Notes:**

1. Refer to section 07840 of the specifications. For Quality Control requirements, refer to the Quality Control portion of the specification.
2. Details shown are typical details. If field conditions do not match requirements of typical details, approved alternate details shall be utilized. Field conditions and dimensions need to be verified for compliance with the details, including but not limited to the following:
  - \* Minimum and maximum Width of Joints
  - \* Type and thickness of fire-rated construction. The minimum assembly rating of the firestop assembly shall meet or exceed the highest rating of the adjacent construction.
3. If alternate details matching the field conditions are not available, manufacturer's engineering judgment drawings are acceptable. Drawings shall follow the International Firestop Council (IFC) Guidelines for Evaluating Firestop Systems Engineering Judgments.
4. References:
  - \* 2017 Underwriter's Laboratories Fire Resistance Directory, Volume 2
  - \* Intertek Directory of Building Products
  - \* All governing local and regional building codes

*Current as of November 19, 2017.  
 System details subject to change without notice.*

<Notes to designer (delete this note after reading and replace with title block information)>  
 1. Any modification to these details could result in an application/system not meeting the UL or Intertek Classification or the intended temperature or fire ratings.  
 2. Details shown are up to date as of February 2015.  
 3. For additional information on the details, refer to the most current "Underwriter's Laboratories Fire Resistance Directory (volume 2.)"

JOB NUMBER: \_\_\_\_\_

DRAWN: \_\_\_\_\_

CHECKED: \_\_\_\_\_

ISSUE DATE: 06-13-2018

REVISIONS: \_\_\_\_\_

SHEET NAME:  
 Residential - Wood Construction-Joints Gypsum Walls

SHEET NUMBER: \_\_\_\_\_